


OUTLINE DRAWING

All dimensions shown in mm. Tolerances = ±1mm.


Cable



Brad Harrison micro



Flying Leads




Note: "X" can equal 0.5, 1.0 or 3.0 metres.

HOUSING SPECIFICATIONS

		Housing			
Thread		1/2" BSP	3/8" BSP	1/2" NPT	3/4"-16 UNJF
Pressure ¹	25 bar / 363 psi maximum				
Sensor Termination	Cable: 0.5m, 1m or 3m lengths (IP67)				
	M12x1 Brad Harrison micro (IP67)				
	Flying leads: 24AWG, 0.2m PTFE wires, 8mm tinned (IP65)				


ELECTRICAL INTERFACE

Cable




Wire	Designation
Red	Vs
White	Output
Black	0V

Brad Harrison micro



Pin	Designation
1	Vs
2	Not connected
3	0V
4	Output

Flying Leads



Wire	Designation
Red	Vs
Green	Output
Blue	0V




1) Using sealing washer/O-ring.


In order to suit any application, these sensors have been designed with various output circuit configurations.

5V—12V_{DC}

Digital Output High in Air




Digital Output Low in Air




10V—45V_{DC}


N-Type High in Air




N-Type Low in Air




P-Type High in Air




P-Type Low in Air



Push Pull High in Air



Push Pull Low in Air




CAUTION: Take care when connecting loads.

The minimum load impedance should not exceed $V_s/\text{max output current}$.

Note: Shorting the output to V_s or $0V$ will result in irreparable damage to the sensor.

 **ORDER INFORMATION**

Generate your specific part number using the convention shown below. Use only those letters and numbers that correspond to the sensor and output options you require — omit those you do not.



Note: Not all combinations are configurable and minimum order quantities (MOQs) may apply in some cases.

<p> CAUTION</p> <p>Do not exceed maximum ratings and ensure sensor(s) are operated in accordance with their requirements.</p> <p>Carefully follow all wiring instructions. Incorrect wiring can cause permanent damage to the device.</p> <p>SST Sensing Ltd recommend using alcohol based cleaning agents. Do NOT use chlorinated solvents such as trichloroethane as these are likely to attack the sensor material.</p> <p>Failure to comply with these instructions may result in product damage.</p>	<p> INFORMATION</p> <p>As customer applications are outside of SST Sensing Ltd.'s control, the information provided is given without legal responsibility. Customers should test under their own conditions to ensure that the equipment is suitable for their intended application. Before use, check that the fluid in which you wish to use these devices is compatible with Stainless Steel and Polysulfone.</p>
--	--

General Note: SST Sensing Ltd. reserves the right to make changes to product specifications without notice or liability. All information is subject to SST Sensing Ltd.'s own data and considered accurate at time of going to print.

